



Safety Technology International Ltd

Taylor House
34 Sherwood Road
Bromsgrove, Worcestershire
B60 3DR England

Tel: +44 (0) 1527 520 999
Fax: +44 (0)1527 501 999
Email: info@sti-emea.com



DECLARATION OF CONFORMITY

The manufacturer of the products covered by this Declaration is:
Safety Technology International Ltd
Taylor House, 34 Sherwood Road, Bromsgrove, Worcestershire, B60 3DR, England.

This declaration of conformity is issued under the sole responsibility of the manufacturer. The Regulations covered by this Declaration:
SI 2012/3032 The Restriction of Hazardous Substances Regulations, as amended

Object of this Declaration: **Global ReSet Range (GLR) (indoor use)**

GLR*01-** Global ReSet Surface no shield (DPCO)**
GLR*21-** Global ReSet Surface with shield (DPCO)**



where "*" denotes colour, text & language variations.

The object of the declaration described above is in conformity with the relevant Statutory Requirements.

Specifications	Ratings
Current Carrying Capacity (Non-Switching)	1A (42V DC) 5A (30V AC)
Terminal Conductor Size	0.5mm – 2.5mm
Operating Temperature	-35°C to +49°C
Housing Material	Polycarbonate

The manufacturer hereby declares under his sole responsibility that the product(s) identified above meet the substance restrictions of RoHS: Pb (0.1%), Hg (0.1%), Cd (0.01%), Cr VI (0.1%), PBB (0.1%), PBDE (0.1%), DEHP (0.1%), BBP (0.1%), DBP (0.1%) and DIBP (0.1%) and comply with the essential requirements of the following designated standards:

Ref No.	Title	Edition/Date
EN 600669-1	Switches for household and similar fixed electrical installations, general requirements	2018

The technical documentation required to demonstrate that the product(s) meet the requirements of these regulations has been compiled and is available for inspection by the relevant enforcement authorities. Last two digits of the year that the UKCA Mark was first affixed: **21**

Signed for and on behalf of the manufacturer by:

.....Steve Hunt..... Managing Director.....
(name and function)

.....STI Ltd, Bromsgrove, 06 April 2022.....
(place and date of issue)

(signature)

ATTENTION

The attention of specifier, purchaser, installer, or user is drawn to special measures and limitations to use which must be observed when these product(s) are taken into service to maintain compliance with the above regulations. Details of these special measures and limitations to use are available on request, and are also contained in the product manual.

